

ADDENDUM No.2
No. 2023-107
Construction of Pavilion at Singing Waters

Date: July 11th, 2023

To Whom It May Concern:

Here are responses from the discussion held during the site visit and from questions asked via email.

Location to clean out concrete trucks?

Trucks can be cleaned out farther up the road, location will be flagged prior to the start of the project.

Header to match the bath house?

Yes, the header of the pavilion should match the bathhouse header.

Wrap the posts to match the bath house?

No the posts will not be wrapped.

Lights

Exterior bulb light dawn to dusk on south end of pavilion.

60-minute timer switch for interior lights of Pavilion lights - 8 LED lights (4 in 2 rows)

Meter box and breaker box location change

Meter box needs to be moved off the pole to a double post and plywood with enough room for the breaker box for the pavilion. Location will be near the current pole and the Power is currently off to the location. National Grid will have to be contacted to turn it back on.

What is the pitch for the trusses? Drawings just say “per owner.”

The Pitch should match the existing bath house which is 7/12

Are we to provide a new electrical service or should we assume, we can pull power from the existing bathhouse service? If we are pulling from the existing bath house, please confirm wire sizing. The 4/0 seems excessive if we are just providing a few lights and a single outlet. Should these be on the same circuit or two separate breakers? Thanks

Please see notes on page 1 of this addendum in regards to meter box and breaker box location change. Per the engineer please provide #8 copper cable in a 1” conduit from the new location of meter box and breaker box to the pavilion, taking into account any preexisting underground utilities.

**Receipt of Addendum Acknowledgement
No. 2023-107
Construction of Pavilion at Singing Waters**

**ADDENDUM ACKNOWLEDGEMENT
ADDENDUM NO. _____**

**Please acknowledge the receipt of the above ADDENDUM issued by the County of Lewis,
by signature and recording the date of receipt below.**

Bidder:

Authorized Signatory: _____ Date:

****NOTE: This form must be included in your bid documents if any
Addendum is issued**