

2024-110 DOWNTOWN STABILIZATION PROJECT-PRE-  
RENOVATION ABATEMENT/ ROOF REPLACEMENT

## Addendum 2

Roof specifics for clarification purposes:

- .060 EPDM roof on DensDeck, no insulation (roofing sub)
- Drywall finish on bottom of rafters (drywall sub)
- Roof insulation between drywall and roof deck (insulation sub)