

**ADDENDUM No.1**  
**No. 2026-103**  
**Courthouse Parking Lot Upgrades**

Date: March 31, 2026  
To Whom It May Concern:


**From questions brought up at the site visit on March 30, 2026.**

Please include as an alternate pricing for a 2x2x2 structure with approximately 30' of 8" corrugated pipe running to the existing structure at the end of retaining wall. The new structure is to be in the center of the drive line, noted AA on the attached map.

**What are the asphalt mixes for top and binder?**

Please use Item #402.25 Course Binder and Item 402.09 Type 7 Top. More details about these two mixes can be found in our highway road bid specs linked below.

[26-02-Hot-Asphalt.pdf](#)



Please reach out if you have any questions.

Brian Hanno  
Lewis County Purchasing Director

7660 North State Street • Lowville, NY 13367 • 315-377-2000 • lewiscountyny.gov

Lewis County is an equal opportunity provider and employer. Complaints of discrimination should be made known to the Lewis County Board of Legislators.

**Receipt of Addendum Acknowledgement  
No. 2026-103  
Courthouse Parking Lot Upgrades**

**ADDENDUM ACKNOWLEDGEMENT  
ADDENDUM NO. \_\_\_\_\_**

**Please acknowledge the receipt of the above ADDENDUM issued by the County of Lewis, by signature and recording the date of receipt below.  
Bidder:**

-----  
**Authorized Signatory: \_\_\_\_\_ Date:**

**\*\*NOTE: This form must be included in your bid documents if any Addendum is issued**